

Balmorel Data Report

Background to
Vietnam Energy
Outlook Report
2019



20-06-2019

This report has been conducted for the **Electricity and Renewable Energy Authority in Vietnam (EREA)** and the **Danish Energy Agency (DEA)**. The report should be cited as *EREA & DEA: Balmorel Data Report. Background to the Vietnam Energy Outlook Report 2019 (2019)*

The report is authored by

Nina Dupont

Mikael Togeby

Ea Energy Analyses

Gammeltorv 8, 6 sal

1457 Copenhagen K

Denmark

T: +45 88 70 70 83

Email: info@eaea.dk

Web: www.eaea.dk

Contents

| | | |
|----------|--|-----------|
| 1 | Introduction and background..... | 4 |
| 2 | The Balmorel model | 5 |
| 2.1 | Investment approach | 5 |
| 2.2 | Time resolution..... | 6 |
| 2.3 | Geographical scope | 7 |
| 3 | Existing and committed system..... | 9 |
| 3.1 | Existing generation capacity | 9 |
| 3.2 | Existing and committed transmission capacity | 13 |
| 4 | Future developments..... | 16 |
| 4.1 | Electricity demand | 16 |
| 4.2 | Import from third countries | 17 |
| 4.3 | Fuels and fuel prices | 18 |
| 5 | Investment options | 20 |
| 5.1 | Technology catalogue..... | 20 |
| 5.2 | Interconnector investment costs | 27 |
| 6 | Fuel and RE resources and potentials | 29 |
| 6.1 | Domestic coal and natural gas..... | 29 |
| 6.2 | Hydro | 31 |
| 6.3 | Biomass and MSW | 32 |
| 6.4 | Onshore wind | 34 |
| 6.5 | Offshore wind | 37 |
| 6.6 | Solar | 38 |
| 6.7 | Renewable energy requirements | 39 |
| | References..... | 41 |
| | Appendix | 43 |
| | Appendix I: Exogenous capacity | 43 |
| | Appendix II: Unit commitment parameters for existing units | 50 |
| | Appendix III: Large hydro characteristics | 53 |

1 Introduction and background

This is a Data Report relating to the project ‘Capacity building within Balmorel and scenarios’. The project is being carried out by Ea Energy Analyses in collaboration with the Institute of Energy (Viện Năng lượng) as part of the Development Engagement 1: “Capacity Development for long-range energy sector planning with Electricity and Renewable Energy Agency of Viet Nam”, currently being conducted under the Energy Partnership Programme between Viet Nam and Denmark (DEPP).

This Data Report documents the data and assumptions used for representing the Vietnamese power sector in the Balmorel modelling framework. This Data Report is prepared as supporting documentation to the Energy Outlook Technical Report (EOR) 2019.

Approach

To identify and quantify benefits and disadvantages of different development scenarios within the Vietnamese power system, the country’s generation and transmission system is modelled based on the concept of least-cost optimization. Several scenarios are set up in consultation with Institute of Energy and the Danish Energy Agency to illustrate the economic consequences of possible future strategies.

All cost data in this report are in USD 2016 real terms.

2 The Balmorel model

The Vietnamese power system analyses are carried out with the Balmorel model, which is a least-cost dispatch power system model. The model is based on a detailed technical representation of the existing power system; all power generation plants are represented on individual basis as well as the interconnected transmission grid.

The output is a least-cost optimisation of all the production and transmission units represented in the model. In addition to simulating least-cost dispatch of generation units, the model simultaneously allows for investments to be made in different new generation units (hydro, coal, gas, wind, solar, biomass etc.) as well as in new interconnectors.

2.1 Investment approach

The Balmorel model is myopic in its investment approach, in the sense that it does not explicitly consider revenues beyond the year of installation. This means that investments are undertaken in each year if the annual revenue requirement (ARR) in that year is satisfied by the market. Construction time is not explicitly considered in the model (although interests during construction are included in the investment costs for new technologies). Capacity appears in the beginning of the year of commissioning. This means that the decision for investment should be considered as taken in an earlier year (considering planning and construction).

A balanced risk and reward characteristic of the market is assumed, which means that the same ARR is applied to most technologies, specifically 0.1175, which is equivalent to 10% internal rate of return for 20 years. This rate should reflect an investor's perspective. For transmission capacity this ARR becomes 0.1023 (10% internal rate of return for 40 years).

It should be stressed that the recommended socio-economic discount rate in many countries is significantly lower than the 10% rate applied in the present study (Germany: 2.2%, Sweden and Norway: 4%, Denmark and Finland: 2-4 %, UK: 1.0-3.5%, EU: 3.5-5.5%¹). Applying a lower discount rate would favour capital-intensive technologies like wind power, nuclear power and solar power.

¹ European Commission (2008): Guide to Cost-Benefit Analysis of investment Projects; Concito (2011): Den samfundsøkonomiske kalkulationsrente – fakta og etik.

er as opposed to, e.g. gas power plants. The current 10% discount rate was agreed upon as an appropriate value.

2.2 Time resolution

The model is set up to analyse the year 2017 as reference year and the period 2020-2050 in 10-year intervals.

To limit the computation time, not all hours of the year are included in the simulation. The dispatch and investment optimisation, both in generation capacity and in transmission capacity, are performed with 14x26 (364) time steps. The 13 seasons represent two-week periods in the year, where the hours are aggregated into 14 intervals representing evening peak demand, afternoon solar peaks, nights, morning etc. A more accurate dispatch optimisation can be analysed in 7x168 (1176) time steps, where all hours of 7 weeks are simulated. The 7 selected weeks of the year are: week 4, 10, 16, 34, 39, 47, 52. The chosen weeks are important in relation to the data profiles included in the model. These weeks were chosen to represent low and high demand, high and low wind and solar generation, dry and wet weeks. This relates to electricity demand, hydro inflow, wind and solar profiles.

2.3 Geographical scope

The model contains data of the electricity system of Vietnam. The map below (Figure 1) illustrates the interconnected power system in Vietnam in 2019.




Figure 1. Current interconnectors in Vietnam (2019).

The country is represented in the Balmorel model as 6 transmission regions, each with its own electricity consumption. The transmission regions are connected by electricity transmission lines with fixed capacity. The six regions are selected to represent in more detail the central region of Vietnam, where a large part of the potential for wind and solar power is located. Moreover, the six regions were chosen in order to represent potential transmission bottlenecks in the system.

To allocate generation capacity to the transmission regions, areas are used. Areas are modelling entities in which generating units are placed. For each area, characteristics such as fuel prices, full load hours and hourly profiles for wind, solar and hydro, hydro-reservoir sizes etc. can be defined. Any area

must be included in exactly one region. Each transmission region contains one or more areas. As such, it is possible to assign different technological properties to power plants within one transmission region by using several areas.




Figure 2: The geographical entity representation structure in the Balmorel model.

In the case of Vietnam, each transmission region has one corresponding area for existing generation and one area for new generation introduced after 2018 in which all generation capacity is allocated, and characteristics of solar and small hydro production are defined. Exceptions are made for all large hydro plants (reservoir plants), each one assigned to a specific area per individual plant to be able to describe their plant-specific inflow profiles, full load hours and reservoir sizes. Wind sites of Vietnam are also modelled in three separate areas per region, where wind speed profiles are assigned.

Electricity balances are given on a regional basis. Hence, for each region an electricity balance must be fulfilled but electricity may be exchanged between regions. Therefore, the transmission, and its constraints, losses and costs, are the motivation for the concept of regions.

3 Existing and committed system

Generation technologies in the Balmorel model can be divided into two groups: exogenous generation and endogenous generation. All exogenous capacity is fed into the model as input and is not the result of model optimization. On top of the exogenous capacity, the model can decide to invest in additional capacity, choosing from a list of options, namely the technology catalogue. This model-based additional capacity is called endogenous.

This chapter will look into exogenous generation and transmission capacity

3.1 Existing generation capacity

The generation capacity of existing and committed (i.e. planned with a high likelihood of being realized) power plants is entered in the model exogenously, meaning that it is put in “by hand” and not optimally “chosen” by the model. The exogenous generation fleet is taken from PDP 7 Revised [1]. A detailed list of all PDP 7 revised power plants implemented in the model is presented in the Appendix I. Existing technologies and planned facilities until 2025 as per PDP 7 revised are entered in the model as exogenous, except for coal-based technologies which are only committed until 2023, as investments are less certain due to public resistance and difficulties finding financing. RE capacities are committed until 2025 based on [2]. The exogenously implemented technologies are shown by fuel type in Figure 3.




Figure 3: Exogenous generation capacity (existing and planned until 2025). The plants are exogenously decommissioned after their technical lifetime.

Existing and committed capacity (by 2025) is shown by region in Figure 4.




Figure 4: Existing and committed capacity per region (by 2025)

Exogenous decommissioning is applied to the existing and committed generation fleet, i.e. the technologies are removed from the model after their life-time has ended.

The existing power plant capacity is based on 2018 statistics. However for solar PV and wind power the development has since then been remarkable due to profitable subsidy schemes. In end of June 2019 the capacity of connected solar PV and wind in Vietnam reached 4.5 GW and 0.45 GW solar PV and wind, respectively, however at this point the EOR19 modelling were already finalised. Comparing with the capacity in the model it shows that in the model year 2020 (the models are not run for 2019) a similar amount of capacity of 4.1GW and 1.4 GW solar PV and wind, respectively, in the model. Thus the solar PV capacity in 2020 in the model is only marginally lower than the realized June 2019 capacity in Vietnam, a correction of this would not in any significant way affect the EOR19 calculation results.

O&M for existing and committed units

Generic assumptions for fixed and variable operation and maintenance (O&M) costs are applied for existing and committed power plants and are uniform across the regions. The costs can be seen in the Table 1 below and are based on data from [3] and [1].

| Generation type | Efficiency | Fixed O&M (\$1000/MW el.) | Variable O&M (\$/MWh el.) | Lifetime (years) |
|-----------------|------------|------------------------------|------------------------------|---------------------|
| Coal | 35-41%* | 21.68 | 2.28 | 30 |
| CCGT | 59% | 26.32 | 2.19 | 30 |
| Oil thermal | 24-44%** | 8.00 | 6.4 | 25 |
| Biomass | 32% | 56.56 | 3.0 | 25 |
| Hydro | FLHs | 45.00 | 0.6 | 40 |
| Wind | FLHs | 79.40 | 0.0 | 25 |
| Solar | FLHs | 15.00 | 0.0 | 25 |
| Pumped hydro | 70% | 15.00 | 2.0 | 20 |
| Coal | 35-41% | 21.68 | 2.28 | 30 |

Table 1: Generic fixed and variable O&M and lifetime for existing and committed power plants.

* Depending on coal grade

** Depending on individual plant

Unit commitment

Unit commitment is implemented in Balmorel as a relaxed mixed integer problem. This means that variables which in the ideal case would be binary values (0 or 1) are represented as linear values (e.g. a unit can be 56% online). Variables in the unit commitment problem include:

- Whether the unit is online or not
- Whether the unit is starting-up or not
- Whether the unit is shutting-down or not

As the modelling includes many different units, the general impact of implementing unit commitment on a large scale in this form will be close to the realistic impact. For modelling dispatch of one specific unit, (non-relaxed) mixed integer programming is recommended.

Unit commitment is implemented with data on unit size, start-up costs and minimum generation, received from [1], for a large number of specific existing technologies, as can be found in Appendix II. For thermal technologies, where no specific data was available, as well as for investment options, the unit commitment parameters are implemented as shown in Table 2, based on [3].

| | | Unit size (MW) | Start-up cost (USD/MW) | Minimum gen. (% of MW) | Ramp up- down (%/hour) | Minimum up (hours) | Minimum down (hours) |
|------|---------------|-------------------|------------------------------|---------------------------------|---------------------------------|-----------------------|----------------------------|
| 2020 | Nuclear | 1000 | 260 | 50% | 1.2 | 6 | 6 |
| | Subcritical | 600 | 180 | 67% | 0.6 | 4 | 2 |
| | Supercritical | 600 | 180 | 75% | 0.6 | 4 | 2 |
| | Ultrasuper | 600 | 180 | 30% | 3.0 | 4 | 2 |
| | CCGT | 250 | 131 | 56% | 4.2 | 4 | 2 |
| | Biomass | 25 | 180 | 30% | 6.0 | 4 | 2 |
| 2030 | Nuclear | 1000 | 260 | 50% | 1.2 | 6 | 6 |
| | Subcritical | 600 | 180 | 25% | 2,1 | 4 | 2 |
| | Supercritical | 600 | 180 | 25% | 2,4 | 4 | 2 |
| | Ultrasuper | 600 | 180 | 25% | 3,0 | 4 | 2 |
| | CCGT | 250 | 131 | 30% | 12,0 | 4 | 2 |
| | Biomass | 25 | 180 | 30% | 6,0 | 4 | 2 |
| 2050 | Nuclear | 1000 | 260 | 50% | 1.2 | 6 | 6 |
| | Subcritical | 600 | 180 | 20% | 2,1 | 4 | 2 |
| | Supercritical | 600 | 180 | 20% | 2,4 | 4 | 2 |
| | Ultrasuper | 600 | 180 | 20% | 3,0 | 4 | 2 |
| | CCGT | 250 | 131 | 15% | 12,0 | 4 | 2 |
| | Biomass | 25 | 180 | 30% | 6,0 | 4 | 2 |

Table 2: Unit commitment parameters for thermal units.

Emission factors

The level of SO₂ and CO₂ emissions per fuel type is determined by the fuel used for power production in each time-period by the individual generation units and the corresponding emission factors. An overview regarding the emission factors employed in the current analysis is provided in Table 3. Coal technologies with CCS remove 90% of the CO₂ emissions in coal.

| Fuel | CO ₂ content (kg/GJ fuel) | SO ₂ content (kg/GJ fuel) |
|-------------|---|---|
| Coal | 95 | 0.714 |
| Natural gas | 56.8 | 0 |
| Fuel oil | 78 | 0.446 |
| Light oil | 74 | 0.023 |
| Coke | 106 | 1.428 |

Table 3: Assumptions regarding the CO₂ and SO₂ content in different fuels per GJ of fuel energy content. Only fuels emitting SO₂ and/or CO₂ have been listed.

Decommissioning

Decommissioning in Balmorel can take place both exogenously and endogenously. As explained above, existing and committed generation is decommissioned.

sioned exogenously by calculating the decommissioning year from the start year. Endogenous decommissioning is not allowed in this study.

Outages

Forced and planned outages are assumed for both existing, committed and candidate power plants. All thermal units are characterized by an 'availability factor' of 90% to reflect the downtime for planned and unplanned outages. For coal power plants this outage rate is set at 80%. This factor is, however, applied as a constant over time, meaning that at any given time 10% (or 20%) of the rated generation capacity is not available. Wind, solar, and hydro are not set to be de-rated due to planned outages, since this is assumed to take place when there is no generation on the unit. Unplanned outages on these units are considered in their yearly energy output (full load hours).

3.2 Existing and committed transmission capacity

The starting point of the interconnected grid within Vietnam comprises all existing and committed interconnectors. The country is divided into 6 transmission regions. These regions are then connected by the transmission grid.

Committed interconnectors are projects that are under construction, projects that are decided and financed, or project planned with a very high likelihood of being realized. . These committed interconnection projects and their net transfer capacities are considered as exogenous capacity just as the existing interconnectors.

The figures below show maps of Vietnam with all existing and committed interconnectors for 2020 and 2030, as in PDP 7 [1].




Figure 5: Existing and committed interconnectors in Vietnam, total capacity in 2020.




Figure 6: Existing and committed interconnectors in Vietnam, total capacity in 2030.

The net transfer capacity of all interconnectors in the model is de-rated by 10% to account for planned and unplanned outages of the lines based on own assumptions.

4 Future developments

4.1 Electricity demand

Annual electricity demand forecasts

The power demand projections used in this study, presented in Figure 7, are supplied by Institute of Energy, as result from the all-sector modelling of the Vietnamese energy system in the TIMES-Vietnam model. Power demand is an output of the latter and is used as input for the Balmorel model. More details can be found in the Technical background report for the EOR [4]. Disaggregation of the national demand over the six transmission regions is based on the regional division used in [5].




Figure 7: Annual electricity demands per transmission region

Demand profiles

Hourly demand profiles are used for all years based on statistics of 2017 [1].




Figure 8: Weekly demands based on hourly demand profile (2017).

4.2 Import from third countries

The import of electricity to Vietnam from third countries is shown in Figure 9. North Vietnam imports electricity from China, while the regions North Central, Centre Central and Highland import from Laos. For the Laos connection, a hydro generation profile was used to represent the expected import from the designated hydro plants in Laos, whereas for China an hourly profile was obtained from [1].




Figure 9: Annual import to Vietnam

The import of electricity from Cambodia does not have clear signals from the government and investors, so import from Cambodia is not considered in this report.

4.3 Fuels and fuel prices

The fuels represented in the model are summarized in Table 4.

| Fuel | Description | Origin | Available |
|-------------------------|------------------------|----------|---------------------|
| Nuclear | Uranium | Imported | Everywhere |
| NG (South-East) | Natural gas | Domestic | South |
| NG (South-West) | Natural gas | Domestic | South |
| NG (Block B) | Natural gas | Domestic | South |
| NG (CVX) | Natural gas | Domestic | Centre Central |
| LNG | Liquidized natural gas | Imported | Everywhere |
| Dom. Coal (4b-5) | Coal (grade 4b or 5) | Domestic | North/North Central |
| Dom. Coal (6) | Coal (grade 6) | Domestic | North/North Central |
| Dom. Coal (7) | Coal (grade 7) | Domestic | North/North Central |
| Imp. Coal | Coal (grade 4) | Domestic | Everywhere |
| Fuel oil | Fuel oil | Imported | Everywhere |
| Light oil | Light oil | Imported | Everywhere |
| Rice husk | Biomass | Domestic | Regional* |
| Straw | Biomass | Domestic | Regional* |
| Bagasse | Biomass | Domestic | Regional* |
| Wood | Biomass | Domestic | Regional* |

Table 4: Fuels used in the Balmorel model, including a description of whether the fuel is imported or domestic, and in which regions the fuel is available

*These fuels are restricted by generation capacity and by fuel potential, see Figure 20.

The fuel prices used in the Balmorel model are shown in Figure 10. These are based on the prices projected in [6], which contains details on price formation, components and assumptions for the projections used. The prices considered are CIF (Cost, Insurance and Freight) prices, i.e. reflecting the cost associated with the fuel while still on board a ship in a Vietnamese harbour. For imported coal and LNG, Vietnam-specific cost add-ons² are added to obtain the fuel prices as seen by the plants.

² Add-ons for coal: domestic shipping fee and transit port fee. Furthermore, differentiation in CIF price is made depending on whether the coal is shipped to the two Northern regions, the two Central regions or the two Southern regions. Add-ons for LNG: terminal and storage fee, transportation and distribution fee, management and profit fee.




Figure 10: Fuel prices. The model also uses wind, sun, hydro and geothermal power, but for those technologies, the “fuel price” is assumed zero.

5 Investment options

In this chapter, investment options for generation and transmission capacity will be discussed together with their characteristics, learning curves, and locations in which they can be invested in. Based on this technology catalogue, the Balmorel model can optimize the additional generation capacity needed to fulfil demand increases and to compensate for exogenous decommissioning of existing or committed capacity. The model will find the least-cost solution by choosing the cost-optimal set of generation technologies and transmission lines.

5.1 Technology catalogue

The Balmorel model has a technology catalogue with a set of power generation technologies available for investment. The investment module allows the model to invest in a range of different technologies including (among others): coal power, gas power (combined cycle plants), small hydro, geothermal, biomass, solar PV and wind power.

Investment technology catalogue

Technical and economic data for the power generation technologies that the model may invest in can be viewed in Table 5. The data is based on [3] as well as some other Vietnamese and international sources. The technology assumptions develop from 2020 to 2050, which means that the costs and efficiencies are assumed to develop depending on the learning curves of the specific technologies. Generally, the technologies develop to have higher efficiencies and lower investments costs.

For the CCGT technologies, the model can invest in units that use domestic natural gas or in units that use imported LNG depending on the region.

Ultra-supercritical coal and advanced-ultra-supercritical coal technologies exist as investment options. A subcritical coal unit exists with carbon-capture storage (CCS) as well, where the unit is more expensive, but the CO₂ emissions are reduced by 90%.

Slow learning curves exist for CCGT technologies, while the learning curves of the investment costs for solar and wind are expected to be steeper.

Battery investments can occur independently for generation/charging capacity and storage size. The investment characteristics are shown in Table 6.

| Technology type | Available (Year) | CAPEX incl. IDC (kUSD/MW) | Fixed O&M (kUSD/MW) | Variable O&M (USD/MWhe l) | Efficiency (%) | Technical lifetime (Years) |
|----------------------------|------------------|------------------------------|------------------------|------------------------------|-------------------|-------------------------------|
| Nuclear | 2030 - 2050 | 6,042 | 20.33 | 0.15 | 33% | 50 |
| Coal subcritical | 2020 - 2029 | 1,316 | 39.40 | 0.70 | 36% | 30 |
| | 2030 - 2049 | 1,422 | 38.20 | 0.12 | 36% | 30 |
| | 2050 | 1,387 | 37.00 | 0.12 | 36% | 30 |
| Coal supercritical | 2020 - 2029 | 1,739 | 41.20 | 0.12 | 37% | 30 |
| | 2030 - 2049 | 1,598 | 40.00 | 0.12 | 38% | 30 |
| | 2050 | 1,551 | 38.70 | 0.11 | 39% | 30 |
| Coal ultra-supercritical | 2030 - 2049 | 1,739 | 54.90 | 0.11 | 43% | 30 |
| | 2050 | 1,681 | 53.20 | 0.10 | 44% | 30 |
| Coal AUSC | 2035 - 2050 | 2,427 | 54.90 | 0.11 | 50% | 30 |
| Coal CCS subcritical | 2030 - 2049 | 5,049 | 141.89 | 2.28 | 36% | 30 |
| | 2050 | 4,923 | 137.43 | 2.28 | 36% | 30 |
| CCGT | 2020 - 2029 | 881 | 29.35 | 0.45 | 52% | 25 |
| | 2030 - 2049 | 812 | 28.50 | 0.13 | 59% | 25 |
| | 2050 | 755 | 27.60 | 0.12 | 60% | 25 |
| Small hydro | 2020 - 2050 | 2,057 | 38.00 | 0.46 | FLHs | 50 |
| Wind (Low wind) | 2020 - 2024 | 2,145 | 50.11 | 5.20 | FLHs | 27 |
| | 2025 - 2029 | 1,915 | 47.56 | 4.92 | FLHs | 28.5 |
| | 2030 - 2039 | 1,687 | 44.92 | 4.63 | FLHs | 30 |
| | 2040 - 2049 | 1,518 | 42.67 | 4.34 | FLHs | 30 |
| | 2050 | 1,349 | 40.26 | 4.04 | FLHs | 30 |
| Wind (Medium wind) | 2020 - 2024 | 2,049 | 47.88 | 4.96 | FLHs | 27 |
| | 2025 - 2029 | 1,830 | 45.44 | 4.70 | FLHs | 29 |
| | 2030 - 2039 | 1,611 | 42.91 | 4.43 | FLHs | 30 |
| | 2040 - 2049 | 1,450 | 40.77 | 4.15 | FLHs | 30 |
| | 2050 | 1,289 | 38.46 | 3.86 | FLHs | 30 |
| Wind (High wind) | 2020 - 2024 | 1,749 | 40.86 | 4.24 | FLHs | 27 |
| | 2025 - 2029 | 1,552 | 38.54 | 3.99 | FLHs | 29 |
| | 2030 - 2039 | 1,359 | 36.18 | 3.73 | FLHs | 30 |
| | 2040 - 2049 | 1,209 | 33.99 | 3.46 | FLHs | 30 |
| | 2050 | 1,064 | 31.76 | 3.18 | FLHs | 30 |
| Solar PV (Low land-costs) | 2020 - 2024 | 1,247 | 9.20 | - | FLHs | 25 |
| | 2025 - 2029 | 1,095 | 8.25 | - | FLHs | 25 |
| | 2030 - 2039 | 942 | 7.30 | - | FLHs | 25 |
| | 2040 - 2049 | 845 | 6.75 | - | FLHs | 25 |
| | 2050 | 747 | 6.20 | - | FLHs | 25 |
| Solar PV (High land-costs) | 2020 - 2024 | 1,333 | 9.20 | - | FLHs | 25 |
| | 2025 - 2029 | 1,177 | 8.25 | - | FLHs | 25 |

| | | | | | | |
|------------|-------------|-------|--------|-------|------|----|
| | 2030 - 2039 | 1,021 | 7.30 | - | FLHs | 25 |
| | 2040 - 2049 | 924 | 6.75 | - | FLHs | 25 |
| | 2050 | 826 | 6.20 | - | FLHs | 25 |
| Geothermal | 2020 - 2029 | 4,675 | 20.00 | 0.37 | 10% | 30 |
| | 2030 - 2049 | 4,229 | 18.50 | 0.34 | 11% | 30 |
| | 2050 | 4,229 | 16.90 | 0.31 | 12% | 30 |
| Biomass | 2020 - 2029 | 1,892 | 47.60 | 3.00 | 31% | 25 |
| | 2030 - 2049 | 1,781 | 43.80 | 2.80 | 31% | 25 |
| | 2050 | 1,558 | 38.10 | 2.40 | 31% | 25 |
| MSW | 2020 - 2029 | 9,949 | 234.70 | 24.10 | 28% | 25 |
| | 2030 - 2049 | 9,263 | 224.80 | 23.40 | 29% | 25 |
| | 2050 | 8,234 | 193.50 | 22.60 | 29% | 25 |
| Tidal | 2020 - 2050 | 2,961 | 21.75 | 4.00 | FLHs | 30 |

Table 5: Power generation technology catalogue. Investment costs for battery and pumped hydro (PH) technologies are shown per MWh storage capacity.

*Investment can either be made for using grade 4b/5 or 6 domestic coal or for using imported coal.

**Investment can either be made for using grade 4b/5 domestic coal or for using imported coal.

***Advanced ultra-supercritical; only imported coal.

^{IV} Investment can either be made for West, East or CVX domestic natural gas or imported natural gas. Domestic natural gas technologies can also use imported natural gas.

^V Generation and charging capacity is one fourth of the storage capacity.

| | Available (Year) | CAPEX incl. IDC (kUSD/MWh) | CAPEX incl. IDC (kUSD/MW) | Fixed O&M (kUSD/MW) | Variable O&M (USD/MWh) | Efficiency (%) | Technical life time (years) |
|---------|------------------|----------------------------|---------------------------|---------------------|------------------------|----------------|-----------------------------|
| Battery | 2020 - 2029 | 270 | 500 | 0.62 | 2.28 | 91% | 20 |
| | 2030 - 2049 | 160 | 300 | 0.62 | 2.06 | 92% | 25 |
| | 2050 | 90 | 140 | 0.62 | 1.83 | 92% | 30 |

Table 6: Battery investment options. The battery is a Li-ion battery. Battery investments can be optimized per MWh and per MW independently.

Interest paid during construction

Interest during construction (IDC) is of importance when evaluating the capital costs of one technology option compared to another. Units with a short construction phase pay less IDC than plants with longer construction time. Most capital cost data on power generation are given in overnight costs, meaning that no IDC is considered. Therefore, the IDC costs are added to the investment costs taken from [3], to ensure that the true costs of technologies are represented in the model.

In this study an IDC calculation approach is used which assumes that all costs are distributed equally during the construction phase. The distribution of costs will be different from one project to another, therefore as a generic assumption this method is considered valid. The following formula is applied when calculating IDC.

$$IDC = a \times \frac{(1+i)^t - 1}{i \times t} \times \left(1 + \frac{i}{2}\right) - a$$

Figure 11: IDC formula. i = interest rate, t = construction time (years), a = invested capital

The IDC has already been included in the investment costs shown in Table 5 with an annuity factor of 10%. Construction times are used as documented in [3].

| Years of construction | Added cost due to IDC |
|-----------------------|-----------------------|
| 1 | 5.0% |
| 1.5 | 7.6% |
| 2 | 10.3% |
| 3 | 15.9% |
| 4 | 21.8% |
| 5 | 28.2% |
| 6 | 35.0% |
| 7 | 42.3% |
| 8 | 50.1% |
| 9 | 58.4% |
| 10 | 67.3% |

Table 7: IDC cost depending on years of construction.

Wind technologies

Three turbine types are implemented as investment options in Balmorel. Their investment and fixed O&M costs have been based on the technology catalogue [3], but adapted to the turbine specifications used in the model. The technology catalogue details costs for a specific development in turbine technology. The turbine characteristics modelled in Balmorel differ from those in the technology catalogue (TC) because they are optimized for the wind resources in Vietnam. To adjust for the differences between the Balmorel turbines and the TC turbines, the investment costs and O&M costs are scaled

according to the diameter size and the hub height. This method is described in [7]. The specific power (SP) and hub heights of the three modelled turbines are shown in Table 8. As the generator size is assumed to increase over the years, the rotor diameter is also expected to increase.

| | SP | Hub height |
|-------------------|-----|------------|
| Low wind class | 200 | 100 |
| Medium wind class | 200 | 90 |
| High wind class | 285 | 85 |

Table 8: Specific power (SP) in W/m² and hub height in m for the 3 onshore wind turbines modelled as investment options.

The Low and the Medium wind class power turbines share the same power curve and differ only in height. The power curves of the wind turbines used in Balmorel are shown in Figure 12.




Figure 12: Power curves used in Balmorel

The power generation is modelled according to the following equation:

$$P = \frac{\gamma}{1 + e^{(-g * K_w * (u - M - \epsilon))}}$$

Where P is the generation share of capacity, u the wind speed, γ is the peak capacity (between 0 and 1), g the growth rate, K_w the smoothing factor, M the max growth and ϵ a reality factor.

The reality factor ϵ has been set to 0.7 as an average value.

The smoothening and peak factor are representing that the power curve should represent many turbines spread over a large region and therefore a smoother power curve should be applied. The smoothening and peak factor are based on region size and shown in Table 9.

| | K_w | γ |
|-----------------------|-------|----------|
| North | 0.80 | 0.95 |
| North Central | 0.90 | 0.98 |
| Centre Central | 0.95 | 0.99 |
| Highland | 0.95 | 0.99 |
| South Central | 0.90 | 0.98 |
| South | 0.90 | 0.98 |

Table 9: Smoothening and peak factor per region.

The offshore wind technology is based on [3], both for the specific power and the hub height (Table 10). Its power curve for 2050 can be seen in Figure 12.

| | SP | Hub height |
|-------------|-----|------------|
| 2020 | 309 | 90 |
| 2030 | 353 | 125 |
| 2050 | 332 | 140 |

Table 10: Specific power (SP) in W/m^2 and hub height in m for the offshore wind turbines modelled as investment options.

Solar technologies

For solar technologies, the generation profile and full load hours are based on irradiation data and temperature data. The technology assumptions made to determine these generation profiles are the following:

- South facing panels, with a tilt of 12°
- 16% efficiency under test conditions
- $0.07\%/^\circ C$ efficiency reduction under temperatures higher than $25^\circ C$
- $1.1 W_p/W_{ac}$
- 10% for other losses (not due to high temperatures)

A learning curve is applied to the FLHs. The relative increase in FLHs is shown in Figure 13, based on the development described in [3].




Figure 13: Relative increase in solar full load hours due to technology improvements.

The model can invest in solar technologies with two different capital costs:

- Low land cost: assumes a cost of 6 USD/m² for land use
- High land cost: assumes a cost of 12 USD/m² for land use

For the land cost calculation, a land use factor of 12 m²/kW_p or 14.4m²/kW_{ac} is assumed based on existing solar PV cases in Vietnam. The land cost is estimated from the feasibility study document of the solar PV projects [1] and decisions on land prices by land use purposes of some potential provinces (average land cost).

Pumped hydro projects

Apart from the generic technologies, the model can also invest in specific large pumped hydro projects with reservoir, which are planned in PDP7 after 2020. These projects are located in a specific region and have a maximum capacity (Table 11). Pumped hydro is assumed to have efficiencies of 80%.

| Project (Area) | CAPEX incl. IDC (kUSD/MWh) | Maximum Turbine/Pump capacity (MW) | Maximum Reservoir capacity (MWh) | MWh/ MW |
|------------------------------------|----------------------------|------------------------------------|----------------------------------|---------|
| Moc Chau PSPP (North) | 92 | 900 | 7,129 | 8 |
| Phu Yen East PSPP (North) | 62 | 1,200 | 17,518 | 15 |
| Phu Yen West PSPP (North) | 105 | 1,000 | 8,502 | 9 |
| Chau Thon PSPP (North Central) | 106 | 1,000 | 8,502 | 9 |
| Don Duong PSPP (Highland) | 107 | 1,200 | 10,479 | 9 |
| Ninh Son PSPP (Highland) | 98 | 1,200 | 10,390 | 9 |
| Ham Thuan Bac PSPP (South Central) | 101 | 1,200 | 10,390 | 9 |
| Bac Ai PSPP (South Central) | 97 | 1,200 | 10,104 | 8 |

Table 11: Specific large hydro projects [8].

Locations for investments

Most technologies can be invested in by the model in all 6 regions. However, some exceptions to this rule apply:

- Nuclear capacity: Only in Centre Central and South Central
- Domestic coal technologies: Only North and North Central
- Domestic NG (East and West) technologies: Only in South
- Domestic NG (CVX gas) technologies: Only in Centre Central

Investment restrictions

Nuclear power plants historically have been characterized by complex development process and lengthy construction timelines. In order to make sure that the modelling results are realistic with regard to the build-out of nuclear capacity, a maximum capacity addition cap is set for every 5-year period, as illustrated in Figure 14.




Figure 14: Nuclear capacity build-out limitations implemented in the Balmorel model.

5.2 Interconnector investment costs

The investment costs for new lines are shown in Figure 15. The investment rate of the transmission lines is taken from the PDP7 revised [5]. Investment costs for each transmission line (\$/MW/km) are assumed as follows:

- 500kV line: 600 \$/MW/km
- 220kV line: 850 \$/MW/km

Based on the distance between regions, the investment cost is estimated in Table 12.

| Connection | Connection Voltage (kV) | Length (km) | Investment cost (\$/MW) |
|--------------------------------------|-------------------------|-------------|-------------------------|
| North - North Central (1-2) | 500 | 300 | 180,000 |
| North Central - Centre Central (2-3) | 500 | 350 | 210,000 |
| Centre Central - Highland (3-4) | 500 | 250 | 150,000 |
| Centre Central - South Central (4-5) | 500 | 350 | 210,000 |
| Highland - South (4-6) | 500 | 300 | 180,000 |
| South Central - South (5-6) | 500 | 250 | 150,000 |
| Highland - South Central (4-5) | 220 | 150 | 127,500 |

Table 12: Voltage levels, lengths and investment costs for each transmission line.




Figure 15: Investment costs in new transmission capacity between the 6 regions

When using higher voltage lines (1000kV AC or 800kV DC), the investment cost will be double compared to the 500kV AC line, but the transmission capacity of the line also will be double. In this way, we still can use the reported investment rate (USD/kW) for transmission investment (Table 12).

6 Fuel and RE resources and potentials

For domestic coal, domestic natural gas, hydro, biomass, MSW, solar PV and wind, investment restrictions are set to account for the limited resource availability. These restrictions are based on best available estimates of different resource potentials and act as upper limits not to be exceeded. These, however, might not necessarily be 'binding' in the model in the sense that the optimization might end up with results well below the potentials.

6.1 Domestic coal and natural gas

For domestic coal and domestic natural gas the restrictions are set on the fuel potential, expressed in energy terms, as presented in Figure 16, Figure 17 and 19. Domestic coal is only found in Northern Vietnam and is represented as two coal grades with different qualities:

- High: High quality and higher fuel price (coal grade 4b and 5)
- Low: Lower quality and lower fuel price (coal grade 6).
- Very Low: Lowest quality and lower fuel price (coal grade 7) - not restricted (only few existing plants use this fuel and there are no investment options)

The domestic coal resources are based on [9].

Two types of domestic natural gas are only used in the South and limited in fuel resource (East and West NG, Figure 17) [10]. The third type (CVX gas) of natural gas is used only in Centre Central and is limited in generation capacity (see Figure 18). A fourth type of domestic natural gas (Block B gas) is only found in the South region but no restrictions are implemented as there is no investment option available for this fuel type.

To represent the take-or-pay contracts in place for natural gas, 95% of the annual domestic natural gas resource available for the power sector must be used for electricity generation. For the domestic coal resource, the same restriction is applied to represent coal use contracts for domestic mines.




Figure 16: Maximum domestic coal use (PJ).




Figure 17: Maximum domestic natural gas use in South (East and West NG, PJ).




Figure 18: Maximum domestic natural gas use in Centre Central (CVX gas, GW).

6.2 Hydro

Hydro resource

There are two types of hydro power plants – hydro run-of-river plants and hydro reservoir plants. For both types the annual generation (ignoring spillages) is set by the full load hours of the area in which the plant is located and the capacity of the plant. Run-of-river plants do not have any reservoir capacity, and therefore must generate in accordance with the water inflow into the plant (though the option for water spillage is still available).

Reservoir plants can store the water and the model will use this functionality to maximise the value of the water. Both run-of-river and reservoir hydro plants are assigned a hydro inflow profile in the model. This profile in combination with the full load hours will correspond to the generation profile of a run-of-river plant, since the water must be used when available for this technology type. For a reservoir plant this profile will tell the model the level of water inflow to the reservoir throughout the year.

Run-of-river plants are modelled per region (one area per region). This means all run-over-river plants in the same region have the same inflow profile and full load hours. All regions see 2850 full load hours for small hydro.

Each existing and committed large hydro plant (modelled as reservoir plant) is modelled in its own area. This means that each plant has its own full load hours and reservoir size (acquired from [1]), as shown in Appendix III. When

no FLHs were available, a regional average was used based on the hydro plants for which data was available.

The reservoir sizes are expressed in the model as percentages of total annual generation and are calculated for the hydro plants for which data was available. For the hydro generation, where no reservoir information was found (including all committed generation), the average for that region was used. Full load hours and reservoir averages are shown in Figure 19.




Figure 19: Full load hours and reservoir size for large hydro (average per region).

The hydro inflow profiles are based on the monthly inflow data received from IE [11] for 69 individual hydro plants and are averaged per region to approximate an inflow profile for the remaining plants (both reservoir and run-of-river).

6.3 Biomass and MSW

Restrictions on biomass-fired power generation capacity have been implemented based on an estimate of biomass resources that could be realistically used for power generation applications [12], as presented in Figure 20.




Figure 20: Resource limits on biomass-fired power generation capacity implemented in the Balmorel model (GW).

Similarly, limitations on the availability of Municipal Solid Waste (MSW), have been implemented [12], presented in Figure 21. The MSW potential has been based on the urban population in each of the 63 provinces and the proportion of solid waste assumed to be available for power production out of the total. A maximum annual capacity factor of 70% is implemented for power plants using MSW.




Figure 21: Resource limits on MSW-fired power plant generation capacity implemented in the Balmorel model (MW).

In addition to the capacity restraints, fuel constraints for bagasse, (all other) biomass and MSW are implemented based on the results from TIMES modelling by [4]




Figure 22: Resource limits on biomass and MSW fuel use implemented in the Balmorel model (PJ) – based on TIMES results.

6.4 Onshore wind

Wind resource

In order to represent the intermittent and variable nature of wind resources, hourly wind speed time series per regional wind class are used in the model. Within the framework of the current study, hourly wind speed time series have been kindly provided by Vestas, as well as DTU Wind (output from the wind resource mapping component of the activity “Resource Mapping and Geospatial Planning Vietnam” under contract to The World Bank, for which no publicly available results were available at the time of writing this report). Hourly wind speed time series of a ‘normal’ wind year (i.e. the year with the median annual average wind speed out of a sample of 9 modelled years) have been selected to be used in the model. The wind speed profiles provided by DTU Wind have been applied in the analysis due to the higher number of data points (63 locations nationally) in the data set obtained.

The wind speed profiles of 18 provinces were used to represent the 18 wind areas (6 regions with 3 wind speed classes each).

The 63 Vietnamese provinces were grouped per region and divided over the wind classed by average annual wind speed by the following classification which matches the wind speed groups 4.5 – 5.5 m/s, 5.5 - 6 m/s, above 6 m/s at a height of 100m instead of 80m (shear factor of 0.175 assumed).

- Low: 4.67 – 5.72 m/s
- Medium: 5.72 – 6.24 m/s

- High: 6.24 m/s and higher

The average annual wind speed per region and per wind class was used to scale the wind speed profile which was closer to this annual wind speed. The resulting provinces and average wind speeds are shown in Table 13.

| Region | Wind Category | Wind speed Province | Average wind speed (at 100m) |
|----------------|---------------|---------------------|------------------------------|
| North | High | Thai Binh | 6.88 |
| | Medium | Ha Giang | 6.12 |
| | Low | Hai Duong | 4.92 |
| North Central | High | Quang Binh | 7.57 |
| | Medium | Ha Tinh | 6.01 |
| | Low | Thanh Hoa | 4.83 |
| Centre Central | High | Quang Ngai | 6.84 |
| | Medium | Thua Thien - Hue | 6.05 |
| | Low | Da Nang City | 4.86 |
| Highland | High | Dak Lak Dac Lac | 7.74 |
| | Medium | Kon Tum | 6.08 |
| | Low | Dac Nong | 5.33 |
| South Central | High | Binh Dinh | 8.28 |
| | Medium | Phu Yen | 6.50 |
| | Low | Binh Thuan | 5.50 |
| South | High | Ca Mau | 7.39 |
| | Medium | Dong Thap | 5.99 |
| | Low | Binh Phuoc | 4.86 |

Table 13: The 18 wind areas in Balmorel, 3 per region and wind category.




Figure 23: Average wind speed (at 100m) per region and wind speed class.

It is important to note that the wind speeds used in the power curves mentioned in section 5.1 on wind technologies, will be at hub height. The average wind speed at hub height can be calculated from the given number as:

$$u_{x \text{ meter}} = u_{100 \text{ meter}} \times \left(\frac{x}{100}\right)^{\alpha}$$

Where x is the hub height and α is the shear factor. The shear factor of a region depends on the roughness and height of the location. For Vietnam they were assumed as shown in Table 14:

| | α |
|----------------|----------|
| North | 0.18 |
| North Central | 0.18 |
| Centre Central | 0.18 |
| Highland | 0.17 |
| South Central | 0.17 |
| South | 0.17 |

Table 14: Shear factor per region.

Wind capacity potential

Land-based wind resource potential estimates have been based on [2], as shown in Table 15. The Low wind speed class has wind speeds between 4.5-5.5m/s, the Medium between 5.5-6 m/s and High wind speed classes 6 m/s and up at a height of 80m.

| (m/s at 80m) → | 4.5-5 | 5-5.5 | 5.5-6 | 6-6.5 | 6.5-7 | 7-7.5 | > 7.5 | Total |
|-------------------|--------|--------|--------|-------|-------|-------|-------|---------|
| North | 9,681 | 2,410 | 421 | 38 | 15 | 0 | 0 | 12,565 |
| North Center | 6,691 | 2,655 | 1,212 | 123 | 28 | 0 | 8 | 10,717 |
| Mid Center | 6,362 | 3,392 | 1,240 | 179 | 57 | 5 | 0 | 11,235 |
| Highland | 34,397 | 27,773 | 14,822 | 3,369 | 154 | 27 | 30 | 80,572 |
| South Center | 12,767 | 7,689 | 4,463 | 2,381 | 973 | 271 | 34 | 28,578 |
| South | 15,070 | 41,518 | 16,765 | 285 | 0 | 0 | 0 | 73,638 |
| Total | 84,968 | 85,437 | 38,923 | 6,375 | 1,227 | 303 | 72 | 217,305 |

Table 15: Wind potential in Vietnam (MW).

The resulting regional potentials divided over the different wind speed classes can be seen in Figure 24.




Figure 24: Resource potentials for onshore wind generation capacity per region and wind speed class implemented in the Balmorel model. Low: 4.5-5.5 m/s, Medium: 5.5-6 m/s, High: over 6 m/s (all at 80 m height).

6.5 Offshore wind

Vietnam displays potential for offshore wind power. In this study, the offshore wind areas close to Ninh Thuan (South Central region) have been considered in the modelling and included as 6 areas (Figure 25) each with a potential of 1000 MW (based on the size of the area). Each of the 6 areas is modelled with individual wind speed profiles based on [13]. Offshore wind shows much higher wind speeds compared to onshore wind (average of 9.73 m/s for the whole area, with area “E” having an average windspeed of 10.31 m/s). Other areas for offshore wind, in addition to the Ninh Thuan region, could be further investigated in future studies.




Figure 25: Offshore wind potential close to Ninh Thuan (South Central).

6.6 Solar

Solar resource

The solar generation profiles in Balmorel are calculated by assigning hourly profiles and full load hours to generate a production profile.

Solar irradiation and temperature profiles for 5 measurement locations are used from the project under the auspices of the ESMAP initiative of the World Bank [14]. These were used to calculate the generation profile assuming solar panels characteristics as described in section 5.1. The resulting solar full load hours of the 6 regions for existing technologies are shown in Figure 26. These full load hours increase in future years due to technology developments as shown in Figure 13.

Solar capacity potential

The solar potentials are based on the draft Vietnam Renewable Energy Development Plan [2], as shown in Table 16. The figures for the high potential case are used in the model, along with the full load hours (existing technologies), as shown in Figure 26. It is assumed that half of this potential can be used at low land costs, and the other half at high land costs. It should be noted that the methodology for the solar potential is roughly estimated and does not include potential increases in connection costs or construction costs (e.g. when moving to areas further away from the transmission grid or roads respectively).

| | Base | High |
|-----------------------|----------------|----------------|
| North | 40 | 6,689 |
| North Central | 100 | 736 |
| Centre Central | 664 | 8,938 |
| High land | 28,289 | 140,466 |
| South Central | 41,549 | 71,422 |
| South | 95,725 | 152,201 |
| Total | 166,367 | 380,452 |

Table 16: Solar potential for a base and high case (MW) [2].




Figure 26: Solar potential and full load hours per region implemented in Balmorel.

6.7 Renewable energy requirements

In the model a renewable energy requirement is enforced. This requirement states that a certain percentage of the total generation in Vietnam needs to be supplied by renewable energy sources.

The shares of renewable energy that need to be achieved for each modelled year are shown in Figure 27 and based on The Renewable Energy Plan, Prime Minister's Decision No. 2068, 2015. The goal of the RE Plan is to increase the contribution of RE in power generation, including large hydro [15].




Figure 27: Renewable energy (RE) goals in Vietnam.

The following fuels are implemented as renewable in the model:

- Wind
- Solar
- Hydro (including large hydro)
- MSW
- Rice husk
- Straw
- Bagasse
- Wood
- Other biomass
- Geothermal
- Tidal

References

- [1] IE, Institute of Energy.
- [2] MOIT, “Draft Vietnam Renewable Energy Development Plan,” 2019.
- [3] EREA & DEA, “Vietnamese Technology Catalogue. Technology data input for power system modelling in Vietnam,” Hanoi, 2019.
- [4] EREA & DEA, “Technical report. Background to the Vietnam Energy Outlook Report 2019,” Hanoi, 2019.
- [5] Institute of Energy, “PDP7-Revised,” MOIT.
- [6] EREA & DEA, “Fuel Price Projections for Vietnam. Background to the Vietnam Energy Outlook Report.,” 2019.
- [7] International Energy Agency, “Task 26 - Impacts of Wind Turbine Technology on the System Value of Wind in Europe,” 2017.
- [8] JICA, “Master plan study for Pumped Storage Hydro power plant and optimization of peak power generation in Vietnam,” 2004.
- [9] Vinacomin, “Vietnam Coal industry development plan up to 2030,” 2016.
- [10] PVN (Vietnam Petroleum Corporation), “Vietnam Gas industry development plan up to 2035,” 2016.
- [11] JICA, EVN, IE, “Study on review of the hydrological data of hydro power projects in Vietnam,” 2004.
- [12] “Viet Nam’s Renewable Energy Development Strategy up to 2020 with an Outlook to 2050,” 2015.
- [13] Van Quang Doan et al., “Offshore wind power potential in Vietnam sea,” *Wind Energy*, 2018.
- [14] World Bank, “Energydata,” November 2018. [Online]. Available: <https://energydata.info/dataset/esmap-solar-measurements-in-vietnam>.
- [15] IEA, “Reducing emissions from fossil-fired generation - Indonesia,

Malaysia and Viet Nam,” International Energy Agency, Paris, 2016.

- [16] S. P. a. I. Staffell, “Renewables Ninja,” 2016. [Online]. Available: <https://beta.renewables.ninja/>.
- [17] D. G. Nguyen, “ “The Potential of Biogas and Biomass from Agriculture and Agro-Industry for Power and Heat Generation in Vietnam”,” 2013.
- [18] T. Dung, Solarlab-Institute of Physics, 2009.
- [19] GIZ, “Wind Data Analysis,” 2013.
- [20] GIZ, “Feasibility studies,” 2015.
- [21] International Energy Agency, “World Energy Outlook,” 2016.
- [22] GIZ, “The Potential of Biogas and Biomass from Agriculture and Agro-Industry for Power and Heat Generation in Vietnam”.
- [23] Institute of Energy, “BÁO CÁO TỔNG KẾT THỰC HIỆN NHIỆM VỤ”.
- [24] IEA Wind Task 26, “Wiser, R., Jenni, K., Seel, J., Hand, M., Lantz, E., and Smith, A. Forecasting Wind Energy Costs & Cost Drivers - The Views of the World's Leading Experts,” 2016.
- [25] Ea Energy Analyses and DHI GRAS, “Macroeconomic Cost-Benefit Analysis for Renewable Energy Integration (interim results),” 2017.
- [26] CIEMAT, CENER and IDAE, “Maps of solar resource and potential in Vietnam,” AECID and MOIT.
- [27] DTU, *Work-in-progress output from the wind resource mapping component of the activity Resource Mapping and Geospatial Planning Vietnam under contract to The World Bank*, 2017.
- [28] Ea Energy Analyses, Institute of Energy, “Long term fuel price projections for Vietnam,” Hanoi, 2019.

Appendix

Appendix I: Exogenous capacity

| Name | Region | Capacity (MW) | Fuel | Start year |
|-------------------------------------|-------------------|---------------|----------------------------------|------------|
| Da Nhim | South - Center | 160 | Hydro | 1964 |
| Thu Duc #1 ST | South | 33 | East FO | 1966 |
| Thu Duc #5 GT | South | 15 | East FO | 1968 |
| Thu Duc #6 GT | South | 15 | East FO | 1969 |
| Thu Duc #2 ST | South | 66 | East FO | 1972 |
| Thu Duc #3 ST | South | 66 | East FO | 1972 |
| Thac Ba | North | 120 | Hydro | 1973 |
| ND Can Tho | South | 33 | FO | 1975 |
| Uong Bi | North | 105 | Domestic coal 4b&5 | 1977 |
| Pha Lai 1 | North | 400 | Domestic coal 4b&5 | 1986 |
| Tri An | South | 400 | Hydro | 1989 |
| Thu Duc #4 GT | South | 23 | East FO | 1989 |
| DRAY HLING | Central Highlands | 28 | Hydro | 1990 |
| Ba Ria GT #1 | South | 23 | East FO | 1991 |
| Ba Ria GT #2 | South | 23 | East FO | 1991 |
| Thu Duc #7 GT | South | 33 | East FO | 1992 |
| Thu Duc #8 GT | South | 33 | East FO | 1992 |
| Hoa Binh | North | 1920 | Hydro | 1994 |
| Vinh Son | South - Center | 66 | Hydro | 1994 |
| SUOI VANG | Central Highlands | 10 | Hydro | 1995 |
| Thac Mo | South | 150 | Hydro | 1995 |
| Phu My 2-1extension | South | 440 | East Gas, East LNG after 2026 | 1999 |
| TBK Can Tho | South | 150 | Diesel | 1999 |
| Hiep Phuoc (IPP) #1 ST | South | 0 | East FO, retired after 2025 | 1999 |
| Hiep Phuoc (IPP) #2 ST | South | 0 | East FO, retired after 2025 | 1999 |
| Hiep Phuoc (IPP) #3 ST | South | 0 | East FO, retired after 2025 | 1999 |
| Song Hinh | South - Center | 70 | Hydro | 2000 |
| Buorbon | South | 24 | Biomass | 2000 |
| Ham Thuan | South - Center | 300 | Hydro | 2001 |
| Da Mi | South - Center | 175 | Hydro | 2001 |
| BaRiaC/C#1GT3x37.5ST56 | South | 168,5 | East Gas, East LNG after 2023 | 2001 |
| Pha Lai 2 | North | 600 | Domestic coal 4b&5 | 2002 |
| Ba Ria C/C#2 GT3x37.5MW, ST1x62M | South | 174,5 | East Gas, East LNG after 2023 | 2002 |
| Can Don | South | 78 | Hydro | 2003 |
| Phu My 2-1 | South | 450 | East Gas, East LNG after 2024 | 2003 |
| Na Loi | North | 9 | Hydro | 2004 |
| Ryninh | Central Highlands | 9 | Hydro | 2004 |
| Amata+Vedan | South | 92 | East FO | 2004 |
| Formosa 1 | South | 150 | Imported coal | 2004 |
| Phu My 1 | South | 1090 | East Gas, East LNG after 2024 | 2004 |
| Na Duong I #1 | North | 55 | Domestic coal 6 | 2005 |
| Na Duong I #2 | North | 55 | Domestic coal 6 | 2005 |
| Phu My 2.2 | South | 720 | East Gas, East LNG | 2005 |

| | | | | |
|----------------------|-------------------|------|-------------------------------------|------|
| | | | after 2027 | |
| Phu My 4 | South | 450 | East Gas, East LNG after 2026 | 2005 |
| Phu My 3 | South | 720 | East Gas, East LNG after 2025 | 2005 |
| C.Ngan 1 | North | 50 | Domestic coal 6 | 2006 |
| North Diesel | North | 40 | Diesel | 2006 |
| SESAN 3 # 1 | Central Highlands | 260 | Hydro | 2006 |
| HCHAN | Central Highlands | 12 | Hydro | 2006 |
| Srok Phu Mieng | South | 51 | Hydro | 2006 |
| Dam Phu My | South | 20 | East Gas | 2006 |
| Suoi Sap | North | 16 | Hydro | 2007 |
| C.Ngan 2 | North | 50 | Domestic coal 6 | 2007 |
| Quang Tri (Rao Quan) | Center-Center | 64 | Hydro | 2007 |
| Yaly | Central Highlands | 720 | Hydro | 2007 |
| SE SAN 3A | Central Highlands | 108 | Hydro | 2007 |
| EAK RONG ROU | Central Highlands | 28 | Hydro | 2007 |
| Ca Mau I CC | South | 750 | PM3-CAA Gas, Block B Gas after 2022 | 2007 |
| Tuyen Quang | North | 342 | Hydro | 2008 |
| Binh Dien | Center-Center | 44 | Hydro | 2008 |
| Hmun | Central Highlands | 15 | Hydro | 2008 |
| Bac Binh | South | 33 | Hydro | 2008 |
| Dai Ninh | South - Center | 300 | Hydro | 2008 |
| Da Dang- Dachamo | Central Highlands | 16 | Hydro | 2008 |
| Bao Loc-Da Siat | Central Highlands | 37 | Hydro | 2008 |
| Nhon Trach I CC | South | 450 | East Gas, East LNG after 2031 | 2008 |
| Ca Mau II CC | South | 750 | PM3-CAA Gas, Block B Gas after 2022 | 2008 |
| Ban Coc | North-Center | 18 | Hydro | 2009 |
| Nam Dong | North | 22 | Hydro | 2009 |
| Uong Bi Extension 1 | North | 300 | Domestic coal 4b&5 | 2009 |
| A Vuong | Center-Center | 210 | Hydro | 2009 |
| Song Con 2 | Center-Center | 63 | Hydro | 2009 |
| Loc dau Dung Quat | Center-Center | 81 | East FO | 2009 |
| PLEI KRONG | Central Highlands | 100 | Hydro | 2009 |
| SONG BA HA | South - Center | 220 | Hydro | 2009 |
| BUONKUOP #1 | Central Highlands | 280 | Hydro | 2009 |
| EAK RONG HNANG | Central Highlands | 64 | Hydro | 2009 |
| SESAN 4 #1 | Central Highlands | 360 | Hydro | 2009 |
| O Mon I #1-FO | South | 330 | West FO, Block B Gas after 2022 | 2009 |
| Son La | North | 2400 | Hydro | 2010 |
| Huong Son 1 | North-Center | 34 | Hydro | 2010 |
| Nam Chien 2 | North | 32 | Hydro | 2010 |
| Thai An | North | 82 | Hydro | 2010 |
| Ho Ho | North-Center | 18 | Hydro | 2010 |
| Ho Bon | North | 18 | Hydro | 2010 |

| | | | | |
|---------------------|-------------------|------|--------------------|------|
| Hai Phong I#1 | North | 300 | Domestic coal 4b&5 | 2010 |
| NĐ Cam Pha I | North | 300 | Domestic coal 7 | 2010 |
| Quang Ninh I #1 | North | 300 | Domestic coal 6 | 2010 |
| Quang Ninh I #2 | North | 300 | Domestic coal 6 | 2010 |
| Son Dong #1 | North | 110 | Domestic coal 6 | 2010 |
| Son Dong #2 | North | 110 | Domestic coal 6 | 2010 |
| Ban Ve (Ban La) | North-Center | 320 | Hydro | 2010 |
| Côa S't | North-Center | 97 | Hydro | 2010 |
| Huong Dien #1,2 | Center-Center | 54 | Hydro | 2010 |
| BUON TUA SRAH | Central Highlands | 86 | Hydro | 2010 |
| SEREPOK 3 #1 | Central Highlands | 220 | Hydro | 2010 |
| Sre Pok 4 (80MW) | Central Highlands | 80 | Hydro | 2010 |
| An Khe-Ka Nak | Central Highlands | 173 | Hydro | 2010 |
| Dong Nai 3 | Central Highlands | 180 | Hydro | 2010 |
| Muong Hum | North | 32 | Hydro | 2011 |
| Su Pan | North | 35 | Hydro | 2011 |
| Seo Chung Ho | North | 22 | Hydro | 2011 |
| Uong Bi Extension 2 | North | 300 | Domestic coal 4b&5 | 2011 |
| Hai Phong I#2 | North | 300 | Domestic coal 4b&5 | 2011 |
| NĐ Cam Pha II | North | 300 | Domestic coal 7 | 2011 |
| Huong Dien #3 | Center-Center | 27 | Hydro | 2011 |
| SE SAN 4A | Central Highlands | 63 | Hydro | 2011 |
| Sre Pok 4A (64MW) | Central Highlands | 64 | Hydro | 2011 |
| Dak Rti | Central Highlands | 144 | Hydro | 2011 |
| Dong Nai 4 | Central Highlands | 340 | Hydro | 2011 |
| Dong Nai 2 | South - Center | 73,5 | Hydro | 2011 |
| Da Dang 2 (34MW) | Central Highlands | 34 | Hydro | 2011 |
| Nhon Trach II CC | South | 750 | East Gas | 2011 |
| Nho Que III | North | 110 | Hydro | 2012 |
| Van Chan | North | 57 | Hydro | 2012 |
| Nam Phang | North | 36 | Hydro | 2012 |
| Nam Phan 5 | North | 34 | Hydro | 2012 |
| Nam Chim | North | 16 | Hydro | 2012 |
| Minh L--ng | North | 22 | Hydro | 2012 |
| Mao Khe I-220MW | North | 220 | Domestic coal 6 | 2012 |
| Song Tranh 2 | Center-Center | 190 | Hydro | 2012 |
| Dak Mi 4 | Center-Center | 195 | Hydro | 2012 |
| A Luoi | Center-Center | 170 | Hydro | 2012 |
| Formosa 2 | South | 150 | Imported coal | 2012 |
| Ban Chat | North | 220 | Hydro | 2013 |
| Nam Chien | North | 200 | Hydro | 2013 |
| Ta Thang | North | 120 | Hydro | 2013 |
| Khe Be | North-Center | 100 | Hydro | 2013 |
| Hua Na | North-Center | 180 | Hydro | 2013 |
| Chiem Hoa | North | 48 | Hydro | 2013 |
| Quang Ninh II #1 | North | 300 | Domestic coal 6 | 2013 |
| Quang Ninh II #2 | North | 300 | Domestic coal 6 | 2013 |

| | | | | |
|----------------------------|-------------------|------|---------------------------------|------|
| Mao Khe II-220MW | North | 220 | Domestic coal 6 | 2013 |
| B, Th-íc 2 | North-Center | 80 | Hydro | 2013 |
| Song Boun 5 | Center-Center | 57 | Hydro | 2013 |
| Song Boun 4A | Center-Center | 49 | Hydro | 2013 |
| New Small HPP-Center-South | Central Highlands | 45 | Hydro | 2013 |
| Dam Bri | Central Highlands | 72 | Hydro | 2013 |
| Ngoi Phat | North | 72 | Hydro | 2014 |
| Ngoi Hut 2 | North | 48 | Hydro | 2014 |
| Nam Muc | North | 44 | Hydro | 2014 |
| Nam Na 2 | North | 66 | Hydro | 2014 |
| Song Bac | North | 42 | Hydro | 2014 |
| Nam Mu | North | 12 | Hydro | 2014 |
| Hai Phong II #1 | North | 300 | Domestic coal 4b&5 | 2014 |
| Hai Phong II #2 | North | 300 | Domestic coal 4b&5 | 2014 |
| Mong Duong II #1 | North | 622 | Domestic coal 6 | 2014 |
| An Khanh #1 | North | 50 | Domestic coal 6 | 2014 |
| Nghi Son #1 | North-Center | 300 | Domestic coal 4b&5 | 2014 |
| Nghi Son #2 | North-Center | 300 | Domestic coal 4b&5 | 2014 |
| Vung Ang I #1 | North-Center | 622 | Domestic coal 6 | 2014 |
| Song Tranh 3 | Center-Center | 62 | Hydro | 2014 |
| Song Tranh 4 | Center-Center | 48 | Hydro | 2014 |
| Song Boun 4 | Center-Center | 156 | Hydro | 2014 |
| Dak Mi 3 | Center-Center | 45 | Hydro | 2014 |
| ND Than Nong Son | Center-Center | 30 | Domestic coal 4b&5 | 2014 |
| DAK DRINH 1 | Center-Center | 125 | Hydro | 2014 |
| Song Giang 2 | South - Center | 37 | Hydro | 2014 |
| Vinh Tan II #1 | South - Center | 622 | Domestic coal 4b&5 | 2014 |
| Lai Chau | North | 1200 | Hydro | 2015 |
| Nam Toong | North | 34 | Hydro | 2015 |
| Nam Na 3 | North | 84 | Hydro | 2015 |
| Mong Duong I #1 | North | 540 | Domestic coal 6 | 2015 |
| Mong Duong I #2 | North | 540 | Domestic coal 6 | 2015 |
| Mong Duong II #2 | North | 622 | Domestic coal 6 | 2015 |
| An Khanh #2 | North | 50 | Domestic coal 6 | 2015 |
| Vung Ang I #2 | North-Center | 622 | Domestic coal 6 | 2015 |
| Formusa HT1 (cogen) | North-Center | 650 | Imported coal | 2015 |
| Dong Nai 5 | Central Highlands | 150 | Hydro | 2015 |
| O Mon I #2-FO | South | 330 | West FO, Block B Gas after 2022 | 2015 |
| Vinh Tan II #2 | South - Center | 622 | Domestic coal 4b&5 | 2015 |
| Duyen Hai I #1 | South | 600 | Imported coal | 2015 |
| Hue Quang | North | 520 | Hydro | 2016 |
| Bac Me | North | 45 | Hydro | 2016 |
| Trung Son | North | 260 | Hydro | 2016 |
| small hydrp center 1 | Center-Center | 45 | Hydro | 2016 |
| Sekaman 1 - 80% (Lào) | Center-Center | 0 | Hydro | 2016 |
| ND than Vedan | South | 60 | Imported coal | 2016 |

| | | | | |
|----------------------|-------------------|-------|--------------------|------|
| Formosa 3 | South | 150 | Imported coal | 2016 |
| Duyen Hai I #2 | South | 600 | Imported coal | 2016 |
| Duyen Hai III #1 | South | 600 | Imported coal | 2016 |
| Nho Que | North | 32 | Hydro | 2017 |
| Nho Que II | North | 48 | Hydro | 2017 |
| Long Tao | North | 42 | Hydro | 2017 |
| Yen Son | North | 70 | Hydro | 2017 |
| Thai Binh I #1 | North | 300 | Domestic coal 4b&5 | 2017 |
| B, Th-íc 1 | North-Center | 60 | Hydro | 2017 |
| Nh¹n H¹c | North-Center | 59 | Hydro | 2017 |
| Chi Khê | North-Center | 41 | Hydro | 2017 |
| Tra Khuc 1 | Center-Center | 36 | Hydro | 2017 |
| Dak Mi 2 | Center-Center | 98 | Hydro | 2017 |
| Song Boung 2 | Center-Center | 108 | Hydro | 2017 |
| Biomass1 | South | 30 | Biomass | 2017 |
| Duyen Hai III #2 | South | 600 | Imported coal | 2017 |
| A Lin | Center-Center | 62 | Hydro | 2018 |
| La Ngau | South | 36 | Hydro | 2018 |
| Dak Mi 1 | Center-Center | 54 | Hydro | 2018 |
| New Hydrp South | South - Center | 100 | Hydro | 2018 |
| Vinh Tan I #1 | South - Center | 600 | Imported coal | 2018 |
| Duyen Hai III #3 | South | 660 | Imported coal | 2018 |
| Vinh Tan IV#1 | South - Center | 600 | Imported coal | 2018 |
| Vinh Tan IV#2 | South - Center | 600 | Imported coal | 2018 |
| Small Hydro | North | 1400 | Hydro | 2018 |
| Small Hydro | North-Center | 600 | Hydro | 2018 |
| Small Hydro | Center-Center | 329,1 | Hydro | 2018 |
| Small Hydro | Central Highlands | 827,9 | Hydro | 2018 |
| PV solar | South - Center | 100 | PV solar | 2018 |
| Wind | South | 100 | Wind | 2018 |
| Wind | South - Center | 80 | Wind | 2018 |
| Song Lo 6 | North | 44 | Hydro | 2018 |
| Song Mien 4 | North | 38 | Hydro | 2018 |
| Thang Long I | North | 600 | Domestic coal 6 | 2018 |
| Thai Binh I #2 | North | 300 | Domestic coal 4b&5 | 2018 |
| Hoi Xuan | North | 102 | Hydro | 2018 |
| Bao Lam 3 | North | 46 | Hydro | 2019 |
| Pac Ma | North | 140 | Hydro | 2019 |
| UPPER KONTUM #1 | Center-Center | 220 | Hydro | 2019 |
| Vinh Tan I #2 | South - Center | 600 | Imported coal | 2019 |
| Vinh Tan IV ext | South - Center | 600 | Imported coal | 2019 |
| Thai Binh II #1 | North | 600 | Domestic coal 4b&5 | 2020 |
| Thai Binh II #2 | North | 600 | Domestic coal 4b&5 | 2020 |
| Hai Duong #2 | North | 600 | Imported coal | 2020 |
| ND Hai Ha 1 (cogen) | North | 150 | Imported coal | 2020 |
| Nam Mo (Viet) | North-Center | 95 | Hydro | 2020 |
| Song Hieu (Ban Mong) | North-Center | 60 | Hydro | 2020 |

| | | | | |
|----------------------------|-------------------|------|-----------------|------|
| Formusa HT2 (cogenaration) | North-Center | 650 | Imported coal | 2020 |
| My Ly | North | 250 | Hydro | 2021 |
| Na Duong II | North | 110 | Domestic coal 6 | 2021 |
| Duyen Hai II #1 | South | 600 | Imported coal | 2021 |
| Duyen Hai II #2 | South | 600 | Imported coal | 2021 |
| Long Phu I #1 | South | 600 | Imported coal | 2021 |
| Long Phu I #2 | South | 600 | Imported coal | 2021 |
| Song Hau I #1 | South | 600 | Imported coal | 2021 |
| Song Hau I #2 | South | 600 | Imported coal | 2021 |
| Hai Duong #1 | North | 600 | Imported coal | 2022 |
| Nam Ma (Lao) | North-Center | 0 | Hydro | 2022 |
| Nghi Son II #1 | North-Center | 600 | Imported coal | 2022 |
| Quang Trach I #1 | North-Center | 600 | Imported coal | 2022 |
| Dak Re | Central Highlands | 60 | Hydro | 2022 |
| Nhon Trach III CC | South | 750 | East LNG | 2022 |
| O Mon III - Lo B | South | 1050 | West Gas | 2022 |
| Nam Dinh I #1 | North | 600 | Imported coal | 2023 |
| Nam Dinh I #2 | North | 600 | Imported coal | 2023 |
| An Khanh II | North-Center | 650 | Domestic coal 6 | 2023 |
| Nghi Son II #2 | North-Center | 600 | Imported coal | 2023 |
| Vung Ang II #1 | North-Center | 600 | Imported coal | 2023 |
| Quang Trach I #2 | North-Center | 600 | Imported coal | 2023 |
| Cong Thanh | North-Center | 600 | Imported coal | 2023 |
| TBKHH Dung Quat #1 | Center-Center | 750 | CVX Gas | 2023 |
| TBKHH Mien Trung 1 | Center-Center | 750 | CVX Gas | 2023 |
| Nhon Trach IV CC | South | 750 | East LNG | 2023 |
| O Mon IV - Lo B | South | 1050 | West Gas | 2023 |
| Vinh Tan III #1 | South - Center | 660 | Imported coal | 2023 |
| ND Hai Ha 2 (cogen) | North | 750 | Imported coal | 2024 |
| Vung Ang II #2 | North-Center | 600 | Imported coal | 2024 |
| Quynh Lap I #1 | North-Center | 600 | Imported coal | 2024 |
| ND Quang Tri I #1 | Center-Center | 600 | Imported coal | 2024 |
| TBKHH Dung Quat #2 | Center-Center | 750 | CVX Gas | 2024 |
| TBKHH Mien Trung 2 | Center-Center | 750 | CVX Gas | 2024 |

Appendix II: Unit commitment parameters for existing units

Suffix legend: CO: coal plant, NG: natural gas plant, FO: fuel oil plant, BIO: biomass plant.

| Balmorel name | Unit size (MW) | Start-up cost (USD/MW) | Minimum generation (% of MW) |
|----------------------|----------------|------------------------|------------------------------|
| Pha_Lai_1_CO | 100 | 91 | 60% |
| Pha_Lai_2_CO | 300 | 119 | 83% |
| Uong_Bi_CO | 53 | 185 | 75% |
| Hai_Phong_I1_CO | 300 | 343 | 77% |
| Hai_Phong_I2_CO | 300 | 343 | 77% |
| Hai_Phong_II_1_CO | 300 | 343 | 77% |
| Hai_Phong_II_2_CO | 300 | 343 | 77% |
| Quang_Ninh_I_1_CO | 300 | 173 | 77% |
| Quang_Ninh_I_2_CO | 300 | 173 | 77% |
| Quang_Ninh_II_1_CO | 300 | 173 | 77% |
| Quang_Ninh_II_2_CO | 300 | 173 | 77% |
| Nghi_Son_1_CO | 300 | 194 | 75% |
| Nghi_Son_2_CO | 300 | 194 | 75% |
| Vinh_Tan_II_1_CO | 622 | 249 | 75% |
| Vinh_Tan_II_2_CO | 622 | 249 | 75% |
| Duyen_Hai_I_1_CO | 600 | 249 | 65% |
| Duyen_Hai_I_2_CO | 600 | 249 | 65% |
| Mong_Duong_I_1_CO | 540 | 896 | 63% |
| Mong_Duong_I_2_CO | 540 | 896 | 63% |
| Thu_Duc_1_ST_FO | 33 | 71 | 39% |
| Thu_Duc_2_ST_FO | 66 | 71 | 39% |
| Thu_Duc_3_ST_FO | 66 | 71 | 39% |
| O_Mon_I_1_FO_FO | 330 | 64 | 20% |
| O_Mon_I_2_FO_FO | 330 | 64 | 20% |
| Ba_Ria_CC2_GT3_37_NG | 58 | 31 | 50% |
| Phu_My_2_1_NG | 225 | 18 | 50% |
| Phu_My_1_NG | 545 | 19 | 50% |
| Phu_My_4_NG | 225 | 12 | 50% |
| Thu_Duc_4_GT_FO | 23 | 4 | 49% |
| Thu_Duc_5_GT_FO | 15 | 4 | 49% |
| Thu_Duc_6_GT_FO | 15 | 4 | 49% |
| Thu_Duc_7_GT_FO | 33 | 4 | 49% |
| Thu_Duc_8_GT_FO | 33 | 4 | 49% |
| Coa_t_HRS | 49 | 305 | 70% |
| Son_Dong_1_CO | 110 | 129 | 65% |
| Son_Dong_2_CO | 110 | 129 | 65% |
| Mao_Khe_I_CO | 220 | 129 | 85% |
| Mao_Khe_II_CO | 220 | 129 | 85% |
| Mong_Duong_II_1_CO | 622 | 249 | 65% |
| Mong_Duong_II_2_CO | 622 | 249 | 65% |
| Formusa_HT1_cogen_CO | 130 | 179 | 65% |
| An_Khanh_1_CO | 25 | 297 | 75% |

| | | | |
|---------------------|-----|-----|-----|
| Formosa_1_CO | 150 | 360 | 65% |
| Formosa_2_CO | 150 | 360 | 65% |
| Formosa_3_CO | 150 | 360 | 65% |
| Phu_My_3_NG | 240 | 20 | 46% |
| Phu_My_2_2_NG | 240 | 20 | 50% |
| Nhon_Trach_I_CC_NG | 150 | 13 | 50% |
| Nhon_Trach_II_CC_NG | 250 | 44 | 40% |
| Ca_Mau_I_CC_NG | 250 | 32 | 51% |
| Ca_Mau_II_CC_NG | 250 | 32 | 51% |
| Buorbon_BIO | 12 | 299 | 70% |
| Dam_Phu_My_NG | 20 | 21 | 50% |
| Duyen_Hai_III_1_CO | 600 | 249 | 70% |
| Duyen_Hai_I_2_CO | 600 | 249 | 70% |
| Thai_Binh_I_1_CO | 150 | 194 | 70% |
| Vinh_Tan_IV1_CO | 600 | 251 | 75% |
| Vinh_Tan_IV2_CO | 600 | 251 | 75% |
| An_Khanh_2_CO | 50 | 244 | 75% |

Appendix III: Large hydro characteristics

Note: reservoir is expressed in water capacity in energy terms (GWh) as a percentage of the annual generation of the hydro plant.

| Name | Region | FLHs | Reservoir |
|--------------|---------------|-------|-----------|
| Bac Me | North | 4.378 | 25% |
| Ban Chat | North | 3.549 | 53% |
| Chiem Hoa | North | 4.104 | 25% |
| Ho Bon | North | 3.889 | 25% |
| Hoa Binh | North | 5.263 | 17% |
| Hue Quang | North | 3.662 | 0% |
| Lai Chau | North | 3.892 | 3% |
| Long Tao | North | 3.429 | 25% |
| Minh L--ng | North | 3.727 | 25% |
| Muong Hum | North | 3.656 | 25% |
| Na Loi | North | 3.556 | 25% |
| Nam Chien | North | 3.635 | 26% |
| Nam Chien 2 | North | 4.125 | 25% |
| Nam Chim | North | 3.625 | 25% |
| Nam Dong | North | 3.864 | 25% |
| Nam Mu | North | 3.250 | 25% |
| Nam Muc | North | 3.614 | 25% |
| Nam Na 2 | North | 3.500 | 25% |
| Nam Na 3 | North | 3.452 | 25% |
| Nam Phan 5 | North | 4.176 | 25% |
| Nam Phang | North | 3.500 | 25% |
| Nam Toong | North | 3.882 | 25% |
| Ngoi Hut 2 | North | 3.479 | 25% |
| Ngoi Phat | North | 3.500 | 25% |
| Nho Que | North | 4.344 | 25% |
| Nho Que II | North | 4.104 | 25% |
| Nho Que III | North | 3.809 | 25% |
| Seo Chung Ho | North | 3.000 | 25% |
| Son La | North | 3.741 | 23% |
| Song Bac | North | 3.833 | 25% |
| Su Pan | North | 3.571 | 25% |
| Suoi Sap | North | 3.813 | 25% |
| Ta Thang | North | 2.333 | 25% |
| Thac Ba | North | 3.250 | 53% |
| Thai An | North | 3.841 | 25% |
| Trung Son | North | 3.900 | 25% |
| Tuyen Quang | North | 3.947 | 21% |
| Van Chan | North | 3.842 | 25% |
| Yen Son | North | 2.900 | 25% |
| B, Th-íc 1 | North_Central | 2.333 | 25% |
| B, Th-íc 2 | North_Central | 3.538 | 25% |
| Ban Coc | North_Central | 3.611 | 25% |

| | | | |
|-----------------------|----------------|-------|-----|
| Ban Ve (Ban La) | North_Central | 3.519 | 38% |
| Chi Khê | North_Central | 3.585 | 25% |
| Cõa S't | North_Central | 4.227 | 32% |
| Ho Ho | North_Central | 3.833 | 25% |
| Hua Na | North_Central | 4.017 | 17% |
| Huong Son 1 | North_Central | 3.176 | 25% |
| Khe Be | North_Central | 3.970 | 11% |
| Nh'n H'c | North_Central | 3.203 | 25% |
| A Lin | Center_Central | 3.000 | 19% |
| A Luoi | Center_Central | 3.359 | 19% |
| A Vuong | Center_Central | 4.471 | 22% |
| Binh Dien | Center_Central | 4.273 | 27% |
| DAK DRINH 1 | Center_Central | 3.600 | 37% |
| Dak Mi 1 | Center_Central | 4.426 | 19% |
| Dak Mi 2 | Center_Central | 4.235 | 19% |
| Dak Mi 3 | Center_Central | 5.089 | 19% |
| Dak Mi 4 | Center_Central | 3.938 | 19% |
| Huong Dien #1,2 | Center_Central | 3.333 | 7% |
| Huong Dien #3 | Center_Central | 3.333 | 7% |
| Quang Tri (Rao Quan) | Center_Central | 3.813 | 19% |
| Sekaman 1 - 80% (Lào) | Center_Central | 3.724 | 19% |
| Song Boun 2 | Center_Central | 3.861 | 19% |
| Song Boun 4 | Center_Central | 3.154 | 14% |
| Song Boun 4A | Center_Central | 6.286 | 19% |
| Song Boun 5 | Center_Central | 3.596 | 19% |
| Song Con 2 | Center_Central | 4.286 | 19% |
| Song Tranh 2 | Center_Central | 3.158 | 19% |
| Song Tranh 3 | Center_Central | 3.774 | 19% |
| Song Tranh 4 | Center_Central | 3.750 | 19% |
| Tra Khuc 1 | Center_Central | 3.750 | 19% |
| An Khe-Ka Nak | Highland | 3.237 | 13% |
| Bao Loc-Da Siat | Highland | 3.054 | 13% |
| BUON TUA SRAH | Highland | 3.000 | 30% |
| BUONKUOP #1 | Highland | 3.354 | 0% |
| Da Dang 2 (34MW) | Highland | 3.794 | 13% |
| Da Dang- Dachamo | Highland | 3.125 | 13% |
| Dak Rti | Highland | 2.854 | 13% |
| Dam Bri | Highland | 4.194 | 13% |
| Dong Nai 3 | Highland | 3.222 | 40% |
| Dong Nai 3 | Highland | 3.222 | 40% |
| Dong Nai 4 | Highland | 3.441 | 1% |
| Dong Nai 5 | Highland | 3.753 | 1% |
| DRAY HLING | Highland | 2.786 | 13% |

| | | | |
|-------------------|---------------|-------|------|
| EAK RONG HNANG | Highland | 3.031 | 13% |
| EAK RONG ROU | Highland | 3.536 | 13% |
| HCHAN | Highland | 3.750 | 13% |
| Hmun | Highland | 3.667 | 13% |
| PLEI KRONG | Highland | 4.270 | 21% |
| Ryninh | Highland | 3.444 | 13% |
| SE SAN 3A | Highland | 3.861 | 13% |
| SE SAN 4A | Highland | 3.873 | 13% |
| SEREPOK 3 #1 | Highland | 4.950 | 4% |
| SEREPOK 3 #1 | Highland | 4.950 | 4% |
| SESAN 3 # 1 | Highland | 4.458 | 1% |
| SESAN 4 #1 | Highland | 3.189 | 4% |
| Sre Pok 4 (80MW) | Highland | 3.625 | 13% |
| Sre Pok 4A (64MW) | Highland | 3.313 | 13% |
| SUOI VANG | Highland | 3.500 | 13% |
| Yaly | Highland | 4.806 | 12% |
| Da Mi | South_Central | 3.331 | 48% |
| Da Nhim | South_Central | 5.688 | 48% |
| Dai Ninh | South_Central | 3.287 | 45% |
| Dong Nai 2 | South_Central | 4.762 | 48% |
| Ham Thuan | South_Central | 3.240 | 40% |
| SONG BA HA | South_Central | 4.186 | 3% |
| Song Giang 2 | South_Central | 2.919 | 48% |
| Song Hinh | South_Central | 4.957 | 36% |
| Vinh Son | South_Central | 4.652 | 117% |
| Bac Binh | South | 7.030 | 20% |
| Can Don | South | 4.000 | 20% |
| La Ngau | South | 4.417 | 20% |
| Srok Phu Mieng | South | 4.255 | 20% |
| Thac Mo | South | 4.940 | 20% |
| Tri An | South | 4.428 | 20% |